



Product Service

CERTIFICATE

No. Z2 118390 0001 Rev. 01

Holder of Certificate: **Voxery Unipessoal Lda**

Quinta da bergerie Prenedores
Sao Pedro Do Sul
3660-068 Carvalhais sps
PORTUGAL

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262219301-01

Valid until: 2028-07-24

Date, 2023-09-18

(Zhulin Zhang)

CERTIFICATE

No. Z2 118390 0001 Rev. 01

Model(s):

Evosolar-S144/M6H-xxx (xxx=415-460, in step of 5W);
 Evosolar-S120/M6H-xxx (xxx=345-380, in step of 5W);
 Evosolar-S144/FNH-xxx-HV (xxx=395-420, in step of 5W);
 Evosolar-S120/FNH-xxx-HV (xxx=330-350, in step of 5W);
 Evosolar-S156/M6H-xxx (xxx=450-495, in step of 5W);
 Evosolar-S132/M6H-xxx (xxx=380-420, in step of 5W);
 Evosolar-S108/M6H-xxx (xxx=315-340, in step of 5W);
 Evosolar-S156/M10H-xxx (xxx=560-620, in step of 5W);
 Evosolar-S144/M10H-xxx (xxx=530-575, in step of 5W);
 Evosolar-S132/M10H-xxx (xxx=480-525, in step of 5W);
 Evosolar-S120/M10H-xxx (xxx=435-480, in step of 5W);
 Evosolar-S108/M10H-xxx (xxx=390-430, in step of 5W);
 Evosolar-S144/M6H-xxx-BG (xxx=440-465, in step of 5W);
 Evosolar-S132/M6H-xxx-BG (xxx=405-425, in step of 5W);
 Evosolar-S120/M6H-xxx-BG (xxx=370-385, in step of 5W);
 Evosolar-S108/M6H-xxx-BG (xxx=330-345, in step of 5W);
 Evosolar-S132/M12H-xxx (xxx=650-670, in step of 5W);
 Evosolar-S120/M12H-xxx (xxx=590-605, in step of 5W);
 Evosolar-S110/M12H-xxx (xxx=545-555, in step of 5W);
 Evosolar-S100/M12H-xxx (xxx=495-505, in step of 5W);
 Evosolar-S144/M10H-xxx-BG (xxx=505-545, in step of 5W);
 Evosolar-S132/M10H-xxx-BG (xxx=465-500, in step of 5W);
 Evosolar-S120/M10H-xxx-BG (xxx=420-455, in step of 5W);
 Evosolar-S108/M10H-xxx-BG (xxx=380-405, in step of 5W);
 Evosolar-S132/M12H-xxx-BG (xxx=630-660, in step of 5W);
 Evosolar-S120/M12H-xxx-BG (xxx=570-600, in step of 5W);
 Evosolar-S108/M12H-xxx-BG (xxx=510-540, in step of 5W);
 Evosolar-S110/M12H-xxx-BG (xxx=525-550, in step of 5W);
 Evosolar-S100/M12H-xxx-BG (xxx=480-500, in step of 5W);
 Evosolar-S132/M12N-xxx-BG (xxx=660-690, in step of 5W);
 Evosolar-S120/M12N-xxx-BG (xxx=600-625, in step of 5W);
 Evosolar-S110/M12N-xxx-BG (xxx=550-575, in step of 5W);
 Evosolar-S100/M12N-xxx-BG (xxx=500-520, in step of 5W);
 Evosolar-S132/M12N-xxx (xxx=660-690, in step of 5W);
 Evosolar-S120/M12N-xxx (xxx=600-625, in step of 5W);
 Evosolar-S110/M12N-xxx (xxx=550-575, in step of 5W);
 Evosolar-S100/M12N-xxx (xxx=500-520, in step of 5W);
 Evosolar-S144/M10N-xxx-BG (xxx=555-585, in step of 5W);
 Evosolar-S120/M10N-xxx-BG (xxx=465-485, in step of 5W);
 Evosolar-S108/M10N-xxx-BG (xxx=415-435, in step of 5W);
 Evosolar-S144/M10N-xxx (xxx=555-585, in step of 5W);
 Evosolar-S120/M10N-xxx (xxx=465-485, in step of 5W);
 Evosolar-S108/M10N-xxx (xxx=415-435, in step of 5W);
 xxx is standing for rated output power at STC.

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790



CERTIFICATE

No. Z2 118390 0001 Rev. 01

**Tested
according to:**

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016